



EXCAVATION

6FT x 9FT HOLE

FROM BOTTOM OF
TANK TO BOTTOM OF:
INLET PIPE - 55"
OUTLET PIPE - 52"

TANK SPECIFICATION

- TOP AND BOTTOM - 4 INCHES THICK
 - SIDE WALL - 3 INCHES THICK
 - BAFFLES - CONCRETE CAST IN PLACES AND VENTED AT TOP
 - INLET BAFFLES - EXTENDS FROM ROOF DOWN 22 INCHES
 - OUTLET BAFFLES - EXTENDS FROM ROOF DOWN 29 INCHES
 - ACCESS LID - 24 INCH LID INTO BOTH ENDS OF TANK
 - INSPECTION PORT - 4 INCH PORT LOCATED ABOVE INLET BAFFLE AREA.
- 1000 GAL. CAPACITY @ 20 3/4 GAL/IN.

PARSONS
INC.

658 HANOVER-KENDALL RD.
HOOKSTOWN, PA. 15050

(724) 899-2933 FAX: (724) 899-3532

1000 GALLON
CONCRETE TANK

NOTE: PRODUCT IS CONSTRUCTED OF VIBRATED	DATE: 06/15/00	SCALE: NTS
FULLY REINFORCED CONCRETE, USING A 6 1/2	DRAWN BY:	DAVID G. WERTZ
BAG/YD. OF HIGH EARLY CEMENT.		